



**DELHI JAL BOARD: GNCTD  
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref.No. D.J.B/CWA/Wzd./2023-24/pald-69-70		
Location /Address of Sample	Tulip International School, 611, 612 & 13, Pooth Khurd, Delhi-Bwana Road, Delhi		
Reference No.	Nil	Ref. Letter Date	20.06.2023
Challan No.	134	Challan Date	22.06.2023
Sample Collection date	22.06.2023	Analysis date	22.06.2023
Any other Information	--	Reporting date	26.06.2023

**TEST RESULTS**

S.No.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.3	1.6
2	pH Value	--	6.5-8.5	No relaxation	7.32	7.34
3	Colour	Pt-Co	5	15	1.0	1.0
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µS/cm	-	-	82	68
6	Total Dissolved Solids	mg/L	500	2000	53	44
7	Total Alkalinity as CaCO <sub>3</sub>	mg/L	200	600	20	18
8	Total Hardness as CaCO <sub>3</sub>	mg/L	200	600	14	10
9	Calcium as Ca	mg/L	75	200	3.2	2.4
10	Magnesium as Mg	mg/L	30	100	1.4	1.0
11	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
12	Nitrate	mg/L	--	45	1.3	1.1
13	Chlorides as Cl	mg/L	250	1000	8.0	8.0
14	Fluoride as F	mg/L	1.0	1.5	0.27	0.23
15	Sulphate as SO <sub>4</sub>	mg/L	200	400	2.8	2.3
16	T. Iron	mg/L	--	1.0	0.06	0.04
17	Residual Chlorine	mg/L	0.2	1.0	BDL	BDL
18	COLIFORM COUNT AT 37° C	MPN/100 mL	Absent	--	0	0

.....End of Report.....

**Remarks: For the tested parameters, above water samples conform drinking Water Specification IS-10500 & is fit for drinking purpose.**

*[Signature]*  
Tested by  
Lab.Tech.

*[Signature]*  
Verified by  
Asstt. Chemist

*[Signature]*  
Authorized by  
Chemist/ACWA  
Water Works Wazirabad

For Tulips International School

*[Signature]*  
Manager

O/c



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT  
NARELA ZONE

No. DHO/NRZ/2023/D-507

Dated: 28/6/23

**SCHOOL HEALTH CERTIFICATE**

**Date of Inspection** : 26.06.2023  
1. Name of School : TULIP INTERNATIONAL SCHOOL,  
2. Address : 611, 612 & 613, POOTH KHURD,  
BAWANA ROAD, DELHI - 110039  
3. No. of Shifts : One Timing 08:00 AM to 02:20 PM

**Accommodation Provided**

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.

THE DRINKING WATER IS DELHI JAL BOARD.


THE TOILET ARRANGEMENT IS SANITARY & HYGENIC AND SUFFICIENT IN NUMBER.

**Remarks :**

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

**THE PRINCIPAL**  
**TULIP INTERNATIONAL SCHOOL**  
**611, 612 & 613, POOTH KHURD,**  
**BAWANA ROAD, DELHI - 110039**

  
28/6/23  
Dy. Health Officer

**Narela Zone**  
Dy. Health Officer

For Tulips International School



Manager